


"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

 Delhi Jal Board	DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL ZONAL LABORATORY (SOUTH) WATER WORKS OKHLA DELHI-110025	 पि. एन. यदुनी क. अ.
	 भारतीय मानक ब्यूरो BUREAU OF INDIAN STANDARDS  IS / ISO 9001 QMS	
Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015		

BACTERIOLOGICAL ANALYSIS REPORT

Dated: 08.06.2026

No. DJB/DTQC/ CWA (W&S)III /ACWA (south)/ Bact/P.S./2026-2027/54-55/02.06.2026

Bacteriological Analysis Report as per IS 10500:2012

To M/S – Daisy Dales Senior Secondary School, E-331A, East of Kailash New Delhi -110065	Party Ref.No./Date: DDS/2026/DJB/7747/20.05.2026 Dept. Challan No. /date: 20/23.05.2026 Dt.of sample collection: 02.06.2026 No. of Sample: Two (02) Collected by: Name- Mr. Maneshwar Dixit Desig. - Bacteriologist
--	---

S.No.	Particulars	Clarity	Residual chlorine	Total Coliform Count/ 100 ml sample
1.	DJB inlet near Canteen	Clear	1.25	ND
2.	Drinking point near Electrician Room	Clear	1.25	ND

*ND- Not Detected

RESULT: Collected water samples as mentioned above were found BACTERIOLOGICALLY SATISFACTORY.




ACWA (SOUTH ZONE)


08/06/26

BACTERIOLOGIST (SOUTH ZONE)




MANESHWAR DIXIT
BACTERIOLOGIST (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi


ASST./BACT.



For Adarsh Sangeet Vidyalaya



General Secretary

For Daisy Dales Sr. Sec. School


Manager



DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



Ref. A.C.W.A.(South)/ Paid/2026-27/P33-34/Challan no 20 Dt 20.05.2026 S. No 8252 Date: 05.06.2026

Daisy Dales Sr. Secondary School
E-33 A, East of Kailash
New Delhi 110065

Date of Sample collection :- 02.06.2026

S.No	Characteristics	Unit	Acceptable Limit	DJB Inlet near Canteen	Drinking Pint near Electrician Room
1.	Clarit2	Unit	5	Clear	Clear
2.	Odour	---	Agreeable	Agreeable	Agreeable
3.	Turbidity	NTU	1	4.27	3.57
4.	pH Value	---	6.5-8.5	7.4	7.4
5.	Conductivity	umho/cm ²	---	217	221
6.	Total Dissolved Solids	mg/L	500	141	144
7.	Phenolphthalein Alkalinity	mg/L	----	Nil	Nil
8.	Total Alkalinity (as CaCO ₃)	mg/L	200	56	58
9.	Total Hardness (as CaCO ₃)	mg/L	200	130	130
10.	Carbonate hardness	mg/L	----	56	58
11.	Non- Carbonate Hardness	mg/L	----	74	72
12.	Calcium Hardness	mg/L	----	64	66
13.	Magnesium Hardness	mg/L	----	66	64
14.	Chloride (as Cl)	mg/L	250	16	16
15.	Ammonia (as Total N)	mg/L	0.5	ND	ND
16.	Nitrite (as N)	mg/L	----	ND	ND
17.	Nitrate	Mg/L	45	3.8	3.8
18.	Sulphate (as SO ₄)	mg/L	200	39	40
19.	Iron	Mg/l	0.3	0.18	0.20
20.	Fluoride	mg/L	1.0	0.04	0.04
21.	Calcium (as Ca)	mg/L	75	25.6	26.4
22.	Magnesium (as Mg)	mg/L	30	15.84	15.36
23.	Free Residual Chlorine	mg/L	0.2	1.25	1.25

ACWA(SOUTH)

CHEMIST

A/CHEMIST

1000.2 and 12.0000

22/6/2026



For Adarsh Sangnet Vidyalaya


General Secretary

For Daisy Dales Sr. Sec. School

Manager



MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT
GREEN PARK, AURBINDO MARG,
NEW DELHI-110016



NO. DHO/SZ/MCD/2026/D-1819

Dated: 20-1-26

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Kuldeep Rana, Public Health Inspector from Public Health Department, South Zone inspected Daisy Dales Sn. Sec. School located at E-331A, East of Kailash, New Delhi- 110065.

It was found that the School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue.

If Building Department or any other Government Agency takes actions against u/a constructions or any dispute, then the Health Certificate will be stand cancelled/ revoked without any further intimation in this regard.

20/01/26
Deputy Health Officer
South Zone
South Zone MCD

Copy to: -

- The Principal
Daisy Dales Sn. Sec. School
E-331A, East of Kailash,
New Delhi- 110065.
- Office Copy



For Daisy Dales Sr. Sec. School

Manager

For Adarsh Sangeet Vidyalaya

General Secretary